

**Comfortable and Healthy Indoor Climate EEN-E4001****Exercise 4 for Lecture 4/2019**

Return date 6.2.2019

**1. LCC :**

Carry out a ten years LCC calculation for a filter with the following assumptions.

Interest rate	6%
Air flow	1 m <sup>3</sup> /s (constant)
Running time	6000 hours per year
Fan efficiency	$\eta = 0.5$ (50%)
Energy cost	0.10 €/kWh (increasing 5% per year)

**Filter:**

Investment	80 €including filter, frame and labour cost
Maintenance/ replacement	40 €(no price increase)
Lifetime of filter	6000 hours (1 year)
Average pressure drop	120 Pa
Disposal cost	4 €(increasing 5%)

$$C_p / C_n = [1 + (i - p)]^{-n}$$

where

 $n$  = the number of years $p$  = the price increase $i$  = the interest rate (bank rate or any expected internal rate for investments within the company) $C_n$  = the cost paid after “ $n$ ” years $C_p$  = the present cost of a single cost element,  $C_n$ **2. LCC:**

Calculate the effect for the LCC breakdown if the filter price is doubled (80 €) and the average pressure drop is reduced to 80 Pa. Compare the cost structure of the this design solution to the previous one.

**3. Particle concentration level:**

Dust is generated in the room with a rate of 10 mg/h. The dust concentration of outdoor air is 0.1 mg/m<sup>3</sup>. What is the concentration in the room:

(a) with supply air flow rate of 30 m<sup>3</sup>/h without cleaning the supply air flow

(b) with supply air flow rate of 30 m<sup>3</sup>/h and a filter in supply air flow reducing the concentration of dust in outdoor air with 50%

(c) exhaust airflow rate is constant 30 m<sup>3</sup>/h. There is infiltration of 0.3 l/h in the room of volume of 30 m<sup>3</sup> and the rest of supply air is going through the filter (50 %).

(d) with supply air flow rate of 60 m<sup>3</sup>/h and outdoor air flow of 15 m<sup>3</sup>/h and a filter with efficiency of 50% in outdoor air flow and a filter with efficiency 80% in recirculation air flow

**4.** How much dust accumulates in a filter per week (15 h/d, 5 days a week) if its removal efficiency is 80%, the outdoor air has a concentration of 100 µg/m<sup>3</sup> and the air flow is 1 m<sup>3</sup>/s?